



### OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI/CAN Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on April 14, 2021.

**SealGuard Inc. - a subsidiary of Sub-Technical Inc.**  
363 Mars Valencia Road  
P.O. Box 1178  
Mars, PA 16046  
724-625-0008

Facility: Malcom, IA

#### Joining and Sealing Materials

Trade Designation	Size	Water Contact Temp	Water Contact Material
[1] Grouts			
Hyperflex STI-03-0.15S	[2]	CLD 23	PUR

[1] Minimum cure time is 2 hours at 65°F.

[2] Certified for a maximum of 1% of the surface area of a 9,000 gallon tank or 0.03 sq. in./L.

Facility: Pine Grove, PA

#### Joining and Sealing Materials

Trade Designation	Size	Water Contact Temp	Water Contact Material
[1] Grouts			
Hyperflex STI-03-0.15S	[2]	CLD 23	PUR

[1] Minimum cure time is 2 hours at 65°F.

[2] Certified for a maximum of 1% of the surface area of a 9000 gallon tank or 0.03 sq. in./L.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.